

Architectural Alliance, Incorporated

6654 Phelan Blvd.

Beaumont, TX 77706

409 / 866-7196

Addendum No. 01

Project:

Women's Toilet Facility, Ford Park Softball Complex

Jefferson County, Texas

Job# 0935

Date:

06-08-09

All bidders are herewith notified of the following additions, deletions, changes or clarifications to the drawings dated May 29, 2009 and shall be acknowledged as received on the proposal.

DRAWINGS and SPECIFICATIONS:

- **INVITATION TO BID** 1.
 - a. REVISE 4th paragraph to read:

"A Pre-Bid Conference will be held on Thursday, June 11, 2009 at 10:00 AM CST. The conference will be held at the existing concessions/rest room facility directly adiacent to the jobsite, located at the Ford Park Softball Complex, 5115 IH-10 South, Beaumont, Texas 77705."

- 2. Subgrade/Fill/Site Preparation work shall be performed as described on Sheet S1 (excavation depth of 36 inches, and minimum 36 inches of compacted select fill), IN LIEU OF:
 - a. Geotechnical Investigation, which indicates 24 inches of select fill, with void boxes under grade beams (void boxes shall NOT be used).
 - SECTION 03100 Concrete Formwork, Paragraph 2.1.C, which indicates carton forms (carton forms shall NOT be used).

End of Addendum # 01

Paul N. Hay, A.I.A.

THE AMERICAN INSTITUTE OF ARCHITECTS

Ronald M. Jones, A.I.A.

J. Rob Clark, A.I.A.