



The  
LaBiche  
Architectural  
Group, Inc.

Dohn H. LaBiche, AIA – President  
Greg Wall, AIA

7999 Gladys, Suite 101  
Beaumont, Texas 77706  
(409)860-0197 fax-(409)860-0198

August 17, 2009

HISTORIC RESTORATION OF JEFFERSON COUNTY SUB-COURTHOUSE  
JEFFERSON COUNTY, TEXAS

Project Number 09015

**ADDENDUM NO. 2**

The following changes, corrections and additions or deletions to the Drawings and Specifications are hereby made a part of the Contract Documents. Bidders shall acknowledge receipt of this Addendum in the Proposal Form.

**SPECIFICATIONS**

**GENERAL NOTE:**

1. The building survey drawings A3.0, A3.1 & A3.2 and Architect's Field Report photographs provided to bidders at the pre-bid conference shall be used to identify stone damage in need of repair on the building. The photographs and report shall be used by the contractors to determine the extent of the scope of the work as generically identified on the drawings. Bidders who do not have these documents may request them from the Architect.

**DRAWINGS**

**SHEET A1.0**

**GENERAL NOTES**

1. Add the following notes:
  3. Prior to contractor performing work on existing steel window frames, Owner will provide an inspection report indicating that there are no lead containing paint or other hazardous materials on frames, glazing, etc... If hazardous materials are encountered, the Owner will have them abated prior to contractor beginning restoration work on windows.
  4. Contractor shall be responsible for providing protective pedestrian covers for all entrances where the contractor will be working over the entrances for more than one business day. Owner will close and reroute pedestrian traffic for operations with durations of one business day or less. If construction work over entrances lasts longer than one business day, contractor shall install protective covers at entrances. It shall be the contractor's responsibility to protect the public from any and all dangers caused by the contractor's construction operations.

2. Note 1B:

Replace Note 1B with the following: Contractor shall remove only the broken glass and replace it with 1/4" safety glass in the same color as the original. Contractor shall submit glass samples for approval prior to replacement. All undamaged glass shall be left in place, glazing compound removed and replaced after metal window frame restoration and painting.

SHEET A1.2

1/A1.2 NORTH ELEVATION – HISTORIC COURTHOUSE

1. Add in following note: HVAC ductwork covering steel windows on level 3 shall be removed prior to window restoration and reinstall after restoration by Owner.

-End of Addendum No. 2 -

