



Celebrating 30 years

Architectural Alliance, Incorporated
 6884 Phelan Blvd. Beaumont, TX 77708 409 / 866-7198 Fax 409 / 866-1748

Addendum No. 2

Project:

Hanger No. 2 IRoof & Wall Panel Replacement
 Southeast Texas Regional Airport
 Jefferson County, Texas

Date: 3/3/2010

All bidders are herewith notified of the following additions, deletions, changes or clarifications to the drawings dated February 17, 2010 and shall be acknowledged as received on the proposal.

Project Manual Specification Modifications:

1. DIVISION 07410 – REPLACEMENT PREFORMED HIGH LEG CURVED STANDING SEAM METAL ROOF, WALL PANELS, GUTTERS AND TRIM
 - a. Paragraph 2.1, D, 1; Clarify wall panel dimension is 3" deep x 16" wide with 1½" deep x 5" wide fluting. Where noted on architectural drawings as flush seam metal wall panels, specification for the MBCI wall panel shall govern.

Drawings

1. ARCHITECTURAL DRAWINGS AND DETAILS
 - a. Clarify all wall panels to be MBCI 3" deep x 16" wide, 22 gauge as specified.

End of Addendum # 2



3/3/2010



THE AMERICAN INSTITUTE OF ARCHITECTS
 Ronald M. Jones, A.I.A.

Paul N. Hay, A.I.A.

03/04/2010 14:38 southeast texas regional airport hanger #2 addendum#2 addenda no. 2.doc

J. Rob Clark, A.I.A.
 pg. 1 of 1