



Architectural Alliance, Incorporated

Architectural Alliance, Incorporated
 6654 Phelan Blvd. Beaumont, TX 77706 409 / 866-7198 Fax 409 / 866-1745

Addendum No. 3

Project:

Hanger No. 2 Roof & Wall Panel Replacement
 Southeast Texas Regional Airport
 Jefferson County, Texas

Date: 3/4/2010

All bidders are herewith notified of the following additions, deletions, changes or clarifications to the drawings dated February 17, 2010 and shall be acknowledged as received on the proposal.

Project Manual Specification Modifications:

1. DIVISION 07410 – REPLACEMENT PREFORMED HIGH LEG CURVED STANDING SEAM METAL ROOF, WALL PANELS, GUTTERS AND TRIM
 - a. Paragraph 2.1, C, 5, (a);
 - i. Change to read omit MBCI Double Lock Seam roof system as approved manufacturer. Manufacturer cannot provide a curved double locked standing seam panel.)
 - ii. Add Berridge Z standing seam roof panel with option for double seaming as approved manufacturer of curved standing seam 22 gauge roof panels for this project.

End of Addendum # 2



THE AMERICAN INSTITUTE OF ARCHITECTS
 Ronald M. Jones, A.I.A.

Paul N. Hay, A.I.A.

6654 Phelan Blvd. Beaumont, TX 77706 409 / 866-7198 Fax 409 / 866-1745

J. Rob Clark, A.I.A.

pg. 1 of 2