

Addendum 3

**Jefferson County Regional Marine Security Center
At
Port of Sabine Pass
Sabine Pass, Texas**

November 23, 2011

TECHNICAL SPECIFICATIONS

- SECTION 316219 – TIMBER PILES
 - Modified Items
 - 2.1 TIMBER PILES
 - A.1 Modify to read, “ Species Treated Southern yellow pine. Retain 0.80 CCA (lbs/cu. Ft.) for land based use and 2.5 CCA (lbs/cu. Ft.) for marina use.

BIDDER REQUEST FOR INFORMATION

- The trusses for the boat dock are to be non treated southern yellow pine correct? The specifications do not mention anything about treating them but the drawings say “All wood framing, decking boards, handrails & stair members shall be treated material approved for ground contact”. (079-1009-S2004)
 - Yes, non treated.
- On plan page A2.1, Keynote 16 calls for a “recessed paper towel holder/waste receptacle, as shown in drawing 8/A2.1, however drawing 19/A2.1 and drawing 20B/A2.1 shows keynote 16 as being a shower seat. Which is correct?
 - Keynote 16 refers to the paper towel/ waste receptacle. We will need to delete the existing keynote 16 as it appears on 19/A2.1 and 20B/A2.1. The plumbing fixture schedule on sheet ME-2.0 calls out for an accessible shower unit with a seat.
- In lieu of job built wood rafters/joists at the Security building, can we use pre-fabricated trusses?
 - Yes, as long as shop drawings provided and approved by engineer.
- Who moves the Guard Shack?
 - Sabine Pass Port Authority
- Who relocates the existing Jet Dock shown on 079-1009-S2001?
 - Jefferson County
- There is no spec on the exterior metal letters and emblem that are mounted on the building. Is this by the owner?
 - Yes, owner provided, contractor installed.

Addendum 3

**Jefferson County Regional Marine Security Center
At
Port of Sabine Pass
Sabine Pass, Texas**

November 23, 2011

- Drwg. 079-1009-S2001 shows a pre-manufactured 8' gangway. There is no spec on this. Is this owner provided?
 - Yes, owner provided.