



# d.p. Consulting Engineers, Inc.

3727 Doctors Drive  
Port Arthur, TX 77642  
Phone: 409-983-6263  
Fax : 409-983-6265  
Firm Registration: F-3356  
Email : dp@dpengineersinc.com

## ADDENDUM NO. 2

Addendum Issued Date: April 25, 2013

**Cheek Community Sewer Improvements – Cheek Phase III**

**Jefferson County, Texas**

**Bid No.: IFB 13-006/KJS**

**TXCDBG NO. 711281**

d.p. Job No. 112-29B

The following information is offered for clarification or modification to the project information you now hold.

### 1. SPECIAL PROVISION

Special Provision *Paragraph 40* is added and reads as follows:

40. All PVC Sanitary Sewer Force Main piping shall be **GREEN** in color. All HDPE piping shall have a **GREEN** stripe. Detector tape as described in Special Provision *Paragraph 37* is still required.

Received

Date: \_\_\_\_\_

Acknowledged: \_\_\_\_\_

*The changes listed above will be considered part of the Bid Package. Bidders are advised that each Addendum issued must be recognized by signature and a copy of all addenda must be submitted with Bid.*