



**JEFFERSON COUNTY, TEXAS
PURCHASING DEPARTMENT**

1149 Pearl Street – First Floor
Beaumont, Texas 77701
409-835-8593 phone

ADDENDUM TO IFB

IFB Number: IFB 18-060/YS
IFB Title: Hurricane Harvey Repairs and Restoration for Highway 124 Stock Yard Office and Equipment Shed
IFB Due: **11:00 am CDT, Tuesday, January 22, 2019**
Addendum No.: 2 (two)
Issued (Date): January 16, 2019

TO BIDDER: This Addendum is an integral part of the IFB package under consideration by you as a Bidder in connection with the subject matter herein identified. Jefferson County deems all sealed proposals to have been proffered in recognition and consideration of the entire IFB package – **including all addenda**. For purposes of clarification, **receipt of this present Addendum by a Bidder should be evidenced by returning it (signed) as part of the Bidder’s sealed proposal**. If the Proposal has already been received by the Jefferson County Purchasing Department, Bidder should return this addendum in a separate sealed envelope, clearly marked with the IFB Title, IFB Number, and Opening Date and Time, as stated above.

Reason for Issuance of this addendum: Additional answers to questions.

The information included herein is hereby incorporated into the documents of this present Bid matter and supersedes any conflicting documents or portion thereof previously issued.

Receipt of this Addendum is hereby acknowledged by the undersigned Bidder:

ATTEST:

Witness

Witness

Authorized Signature (Bidder)

Title of Person Signing Above

Typed Name of Business or Individual

Approved by _____ Date: _____

Address

January 16, 2019

ADDENDUM NO.2

BID NO.: IFB 18-060/YS

BID NAME: Hurricane Harvey Repairs and Restoration for Highway 124 Stock Yard Office and Equipment Shed

CLARIFICATIONS – QUESTIONS FROM CONTRACTORS

QUESTION 1: Are you still firm on needing a 50” entry door to the offices?

ANSWER: In Addendum No. 1 the door was changed to 48”

QUESTION 2: Will a standard double door with flush bolt kit work as a substitution for the 50” door? ANSWER: No

QUESTION 3: Are we moving the breaker box upstairs as part of the base bid?

ANSWER: No, this is as an alternate