



JEFFERSON COUNTY PURCHASING DEPARTMENT
Deborah L. Clark, Purchasing Agent

1149 Pearl Street
1st Floor, Beaumont, TX 77701

OFFICE MAIN: (409) 835-8593
FAX: (409) 835-8456

Addendum to IFB

IFB NUMBER: IFB 23-033/MR
IFB TITLE: Generator for Justice of the Peace Precinct 7 Building
IFB DUE BY: 11:00 am CT, Wednesday, June 14, 2023
ADDENDUM NO.: 2
ISSUED (DATE): June 7, 2023

To Bidder: This Addendum is an integral part of the IFB package under consideration by you as a Bidder in connection with the subject matter herein identified. Jefferson County deems all sealed bids to have been proffered in recognition and consideration of the entire IFB Specifications Package – *including all addenda*. For purposes of clarification, **receipt of this present Addendum by a Bidder should be evidenced by returning it (signed) as part of the Bidder's sealed bid submission.** If the bid submission has already been received by the Jefferson County Purchasing Department, Bidder should return this addendum in a separate sealed envelope, clearly marked with the IFB Title, IFB Number, and IFB Opening Date and Time, as stated above.

Reason for Issuance of this Addendum: Questions

The information included herein is hereby incorporated into the documents of this present bid matter and supersedes any conflicting documents or portion thereof previously issued.

Receipt of this Addendum is hereby acknowledged by the undersigned Respondent:

ATTEST:

Witness

Witness

Approved by ____ Date: ____

Authorized Signature (Respondent)

Title of Person Signing Above

Typed Name of Business or Individual

Address



JEFFERSON COUNTY PURCHASING DEPARTMENT
Deborah L. Clark, Purchasing Agent

**1149 Pearl Street
1st Floor, Beaumont, TX 77701**

**OFFICE MAIN: (409) 835-8593
FAX: (409) 835-8456**

1. Question: Will we be removing an existing generator? If yes, do we need to haul it away or just put it to the side?

Answer: No.

2. Question: Other than the size of the generator and ATS do you have more requirements or needed spec? (For example, dba of generator, do you need a double walls diesel tank...)

Answer: The only requirements are listed in Section 4: Minimum Specifications (page 37) of the Invitation for Bid.

3. Question: Is it okay to utilize the same slab for the new generator?

Answer: Yes.

4. Question: Will we need to upgrade any panels due to this installation?

Answer: This should be determined by the vendor.

5. Question: Will we need to provide any temporary power while on site?

Answer: Temporary power will need to be supplied if vendor is cutting power to the office buildings.

6. Question: Will our crew be able to use your facilities restrooms while on site or should we provide a portable toilet?

Answer: Restrooms are available for use.

7. Question: Do you have plans or dimension for the needed generator cover? If you don't have plans, just estimated dimension and materials need for the cover (Like CMU, Wood, etc..) would suffice.

Answer: We do not have plans. The dimensions should be determined by the vendor based on the size of the generator. The materials proposed should be determined by the vendor.

8. Question: For the generator size, we would need to know what would be connected to the generator in order to do load calculations, as of now a 100KW sounds good, but with more details we would be able to determine for sure.

Answer: The Justice of the Peace Building 7 and the Election Barn Building will both need to be powered by the generator.