



**JEFFERSON COUNTY PURCHASING DEPARTMENT**  
*Deborah L. Clark, Purchasing Agent*

---

1149 Pearl Street  
1<sup>st</sup> Floor, Beaumont, TX 77701

OFFICE MAIN: (409) 835-8593  
FAX: (409) 835-8456

---

### Addendum to IFB

**IFB NUMBER:** IFB 24-058/MR

**IFB TITLE:** Jefferson County 2024 Concrete Road Repair Project

**IFB DUE BY:** 2:00 pm CT, Tuesday, October 8, 2024

**ADDENDUM NO.:** 2

**ISSUED (DATE):** October 2, 2024

**To Bidder:** This Addendum is an integral part of the IFB package under consideration by you as a Bidder in connection with the subject matter herein identified. Jefferson County deems all sealed bids to have been proffered in recognition and consideration of the entire IFB Specifications Package – *including all addenda*. For purposes of clarification, **receipt of this present Addendum by a Bidder should be evidenced by returning it (signed) as part of the Bidder's sealed bid submission**. If the bid submission has already been received by the Jefferson County Purchasing Department, Bidder should return this addendum in a separate sealed envelope, clearly marked with the IFB Title, IFB Number, and IFB Opening Date and Time, as stated above.

---

**Reason for Issuance of this Addendum: Clarifications, Additions to Specifications and updated Bid Form. Please note, all changes to the Specification Details also applies to the Drawings.**

---

**The information included herein is hereby incorporated into the documents of this present bid matter and supersedes any conflicting documents or portion thereof previously issued.**

---

Receipt of this Addendum is hereby acknowledged by the undersigned Respondent:

**ATTEST:**

---

Authorized Signature (Respondent)

---

Witness

---

Title of Person Signing Above

---

Witness

---

Typed Name of Business or Individual

Approved by \_\_\_\_\_ Date: \_\_\_\_\_

---



**JEFFERSON COUNTY PURCHASING DEPARTMENT**  
*Deborah L. Clark, Purchasing Agent*

---

1149 Pearl Street  
1<sup>st</sup> Floor, Beaumont, TX 77701

OFFICE MAIN: (409) 835-8593  
FAX: (409) 835-8456

---

1. In "Section 5: General Notes and Bid Item Notes", TXDOT Item 100: We added "Tree Removal is only to be performed as directed by the County Engineer. This item may or may not be used." This is found on page 46 of the Bid Specification Packet.
2. In "Section 5: General Notes and Bid Item Notes, TXDOT Item 361: Repair of Concrete Pavement" we added "Work associated with this item shall also meet requirements of TXDOT item 360. Field testing for concrete placement shall be performed at the rate of one (1) set of compressive samples per Project Location shown on the Project Plan Cover Page per day of placement. This is found on page 47 of the Bid Specification Packet.
3. In "Section 6: Governing Construction Specifications", TXDOT Item 360 Concrete Pavement has been added to the "Standard Specifications". This is found on page 50 of the Bid Specification Packet.
4. Clarification: The reinforcing steel applicable to the project, outlined in Table No. 1 on the project plan sheet "Repair of Concrete Pavement REPCP-14" shall follow the requirements for Jointed Reinforced Concrete Pavement (JRCP).
5. Clarification: Vendor is required to design a detour plan.
6. The "Bid Form" has been updated. The revised "Bid Form" is attached.
7. The "Summary of Estimated Quantities" has been updated. The revised "Summary of Estimated Quantities" is attached.



**JEFFERSON COUNTY PURCHASING DEPARTMENT**  
*Deborah L. Clark, Purchasing Agent*

1149 Pearl Street  
1<sup>st</sup> Floor, Beaumont, TX 77701

OFFICE MAIN: (409) 835-8593  
FAX: (409) 835-8456

**BID FORM**

<b>Bid Item</b>	<b>TXDOT Item</b>	<b>Bid Item Description</b>	<b>Unit</b>	<b>Estimated Quantity</b>	<b>Unit Price</b>	<b>Extended Amount (Total for Line Item)</b>
1	100	Tree Removal (Walker Lane)	EA	2.0	\$	\$
2	104	Remove Concrete Paving	SY	612.0	\$	\$
3	132	10" Compacted Structural Fill in Place (includes excavation, proof rolling, backfill and compaction)	SY	232.0	\$	\$
4	162	Block Sodding in Place	SY	50.0	\$	\$
5	247	8" Compacted Limestone Base in Place	SY	232.0	\$	\$
6	247	10" Compacted Limestone Base in Place	SY	378.4	\$	\$
7	251 361	6" Concrete (HES) in Place	SY	610.4	\$	\$
8	529	Concrete Curb in Place	LF	292.0	\$	\$
9	351	Soft Spot Subgrade Repair (Only as directed by the Engineer)	SY	40.0	\$	\$
10	N/A	Concrete Downspout Pads (Diamond D Drive)	EA	4.0	\$	\$



**JEFFERSON COUNTY PURCHASING DEPARTMENT**  
*Deborah L. Clark, Purchasing Agent*

1149 Pearl Street  
1<sup>st</sup> Floor, Beaumont, TX 77701

OFFICE MAIN: (409) 835-8593  
FAX: (409) 835-8456

11	500	Mobilization (MAX 3%)	LS	1.0	\$	\$
12	502	Barricades, Signs and Traffic Handling (Diamond D Drive)	LS	1.0	\$	\$
13	502	Barricades, Signs and Traffic Handling (Walker Lane)	LS	1.0	\$	\$
					<b>TOTAL BID AMOUNT</b>	\$

BID ITEM NUMBERS  
SHALL BE  
UNDERSTOOD TO  
MATCH THOSE ON  
THE BID FORM

## SUMMARY OF ESTIMATED QUANTITIES

### Jefferson County 2024 Concrete Road Repair Project

Bid Item	TXDOT Item	BID ITEM DESCRIPTION	Unit	DIAMOND D DRIVE		DIAMOND D DRIVE		DIAMOND D DRIVE		PROJECT BID	
				AREA #1-A	Quantity	AREA #1-B	Quantity	AREA #1-C	Quantity	AREA #1-D	Quantity
1	100	TREE REMOVAL(WALKER LANE)	EA							2.0	2.0
2	104	REMOVE CONCRETE PAVING	SY		348.5	3.7	5.3	21.0	232.0		610.5
3	132	10" COMPACTED STRUCTURAL FILL IN PLACE (includes excavation, proof rolling, backfill and compaction)	SY						232.0		232.0
4	162	BLOCK SODDING IN PLACE	SY		27.0					23.0	50.0
4	247	8" COMPACTED LIMESTONE BASE IN PLACE	SY							232.0	232.0
5	247	10" COMPACTED LIMESTONE BASE IN PLACE	SY		348.5	3.7	5.3	20.9			378.4
5	361 251	6" CONCRETE (HES) IN PLACE	SY		348.5	3.7	5.3	20.9	232.0		610.4
6	529	CONCRETE CURB IN PLACE	LF		157.0					135.0	292.0
7	351	SOFT SPOT SUBGRADE REPAIR (ONLY AS DIRECTED BY THE ENGINEER)	SY		20.0					20.0	40.0
8	N/A	CONCRETE DOWNSPOUTS (DIAMOND D DRIVE)	EA		4.0						4.0
9	500	MOBILIZATION (MAX 3%)	LS								1.0
10	502	BARRICADES, SIGNS AND TRAFFIC HANDLING (Diamond D Drive)	LS		1.0						1.0
11	502	BARRICADES, SIGNS AND TRAFFIC HANDLING (Walker Lane)	LS							1.0	1.0



ADDENDUM #2

JEFFERSON COUNTY ENGINEERING DEPARTMENT JEFFERSON COUNTY COURTHOUSE 1149 PEARL STREET, 5TH FLOOR BEAUMONT, TEXAS 77701 PHONE: (409) 835-8584 FAX: (409) 835-8718	
PROJECT: CONCRETE ROAD REPAIR PROJECT	
SHEET 5 OF 14 DRW'N. BY: G.K.	SHEET: ESTIMATED QUANTITIES
CHK'D. BY: M.F.	Page 5 of 5